

Contact Spray

Introduction

Technical sprays are used in nearly all sectors of modern industry. These sprays are used for care and protection of surfaces, for cleaning, degreasing, dissolving and separating and are essential in daily business.



product in question meets the requested properties are recommended. A claim cannot be derived from them. The user bears the only responsibility for non-appropriate or other than specified applications.

WEICON Contact Spray is based on a special combination of active ingredients for the care and protection of electrical contacts and components.

Dispels moisture from electrical contacts, prevents leakage current and voltage loss and keeps contacts, fuses, cable connections, etc. free of oxidation and sulphide deposits. WEICON Contact Spray is therefore used, for example, in fuse boxes, intercom systems and gate drives, socket outlets, cable and plug connections, cable drums and extensions, electrical garden equipment and lighting systems.

Technical data

Colour	transparent
Odour	solvent
Temperature resistance	-20 to +150 °C
Shelf life (minimum)	24 months
Special features	Dispels moisture, protects electrical contacts

Processing

Only for cleaning switched-off and cooled-off appliances (pull out mains plug). Shake can thoroughly before use. Do not use on energized equipment. Apply a thorough coating at a distance of approx. 5 cm and allow to soak in for approx. 30 seconds. Absorb excess substance with a non-fluffy cloth.

Storage

Pressurized container: protect from sunlight and do not expose to temperatures exceeding +50°C.

Note

The specifications and recommendations given in this technical data sheet must not be seen as guaranteed product characteristics. They are based on our laboratory tests and on practical experience. Since individual application conditions are beyond our knowledge, control and responsibility, this information is provided without any obligation.

We do guarantee the continuously high quality of our products. However, own adequate laboratory and practical tests to find out if the