AD485-A and AD485-C

RS-232 to RS-485 passive converter

User's Guide

I .Sukmmary

In order to communicate between various standard series ports If computers, external equipments, or intelligent instruments, we must convert these signals first. Thes converter is compatible with RS-232C and RS-485 standard.It is able to convert RS-232 signal to RS-485 balanced differential signal and extend the communication distance to 1.2KM.It is passive and doesn't require external power.It uses a particular pump to gain power from RS-232 signals (RTS,DTR,TXD)without initializing the RS-232 series interface.An internal transceiver and particular circuit automatically controls the data stream direction instead of handshake signals(such as RTS,DTR,etc.)When works in RS-232 half-duplex mode, the software keeps the same function under RS-485 without any change. The transmission rate of 300-115200bps is capable of applying between host computers, host computer and its external equipments and forms point ,to point, point to multi-points network. It is widelu used industrial autom ation.door safe, all-in-one-card, car parding, ATM, bus attendance charge, eatery sell out, staff management, and highway toll gate etc.

This guide is suitable for two models:

AD485-C (Standard)

AD485-B (Commercial version)

AD485-A (Industrial version)

II. Features

- Interface:Compatible with ELA RS-232Cstandard and RS-485 standard.
- Electronec interface:At the side of RS-232 is a DB9 male(hole-type)connector,with connection board.
- Working mode: Asynchronous, half-duplex, differential transmission.
- Transmission media:Twisted pair or shielded twisted pair(STP).
- 5. Transmission rate:300-115200bps.
- 6. Mechanical dimension:95mm*33mm*17mm

- 7. Working environments: $0^70 \, ^{\circ}\mathrm{C} \, (AD485-C),-20^58 \, ^{\circ}\mathrm{C} \, (AD485-1).$ relative humidity 5% to 95%.
- Transmission distance:1200m(RS-485),5m(RS-232).

III.Connector and signal definition

1. RS-232C connector definition:

DB9	RS-232C
female	signal
1	DCD
2	RXD
3	TXD
4	DTR
5	GND
6	DSR
7	RTS
8	CTS
9	RI

2. RS-485 connector definition:

PIN number	DB9 Male	RS-485 connection board
1	D-/B	D+/A
2	D+/A	D-/B
3		
4		
5	GND	GND
6	+5V`+12V	+5V`+12V
7		
8		
9		

IV. Hardare installation and application

This converter use traditional DB9/Female and DB9/Male connectors.Output connection board has four poles.You can use twisted pair(TP)or shielded twisted pair(STP)and easily to assemble or disassemble.D+/A is positive signal,D-/B is negative signal,+5V/+6V is external power input if need,GNDis public ground wire. Communication needs at least 2 connections(D+/A,D-/B).Connecting the same polarity signals together.If you use STP,the GND signal must connect too.


This converter supports 2 communication modes as below:

- 1. Point to poent, 2 wires, half-duplex.
- 2. Point to multi-poents, 2 wires, half-duplex.


When thes converter works at the end of the network, it needs to install a terminal resistance (normally $120\,\Omega$, 1/4 W), for preventing signal reflection and interference.

V.Network illustration

1. Point to point, 2 wires, half-duplex



2. Point to muti-points, 2wires, half-duplex



VI. Frequently asked question (FAQ)

- 1. Data communication failure
 - a. Check if RS-232 interface output signal is correct;
 - b. Check if rs-232 output signal is correct;
 - c. Check if connection poles are well connected.
 - 2. Data loss or mistake
 - a.Check if data rate and format is consistent on both communication equipments.

Standard accessory:

User's guide on a paper 1pc
6 poles connection board 1pc